



Electrical Contractors Safety Audit Checklist

Cords and Plugs

- Do extension cords have a grounding conductor?
- Are multiple plug adaptors prohibited?
- Are all temporary circuits protected by suitable disconnecting switches or plug connectors at the junction with permanent wiring?
- Are exposed wiring and cords with frayed or deteriorated insulation repaired or replaced promptly?
- Are flexible cords and cables free of splices or taps?
- Are clamps or other securing means provided on flexible cords or cables at plugs, receptacles, tools, equipment, etc., and is the cord jacket securely held in place?
- Are all cord, cable and raceway connections intact and secure?
- Are all unused openings (including conduit knockouts) in electrical enclosures and fittings closed with appropriate covers, plugs, or plates?
- Are electrical enclosures such as switches, receptacles, junction boxes, etc., provided with tight fitting covers or plates?
- Is the location of electrical power lines and cables (overhead, underground, under floor, other side of walls, etc.) determined before digging, drilling, or similar work is begun?

COMMENTS:
